



rfo-sfps-surat@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOSRT/2023/00035608

Date: 22/01/2026

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOSRT/2023/00035608/R2

Building Occupancy/Category: Educational (non-residential)

To,

RITESH AGRAWAL

1 Koparli Vapi VALSAD Valsad 396145

Fire Region: Surat RFO

Mobile No: 9209462918 Email ID: ritesh.agrawal@dpsvapi.net

We have received Application No.2026/00167639 dated 09/01/2026 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCR) for the building/premise Delhi Public School (name of the Building/Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: Vapi
5. Name of Block(s): Delhi Public School

The building/premise was inspected on 22/01/2026 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 22/01/2026
2. Six monthly inspection was done on 22/01/2026

The Fire Safety Certificate is renewed for a period of two (2) years upto 22/01/2028 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated:20/01/2026 4:13:19 PM



Digitally Verified

Digitally verified by: Hirang Shirishbhai Patel

Fire Safety Officer - General (FSO-G)

2021/001285

Reviewed by : RFO Surat

Date: 22/01/2026

Time: 12:16 PM



FSCA/O/RFOSRT/2023/00035608/R2

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

